



Product Service

# CERTIFICATE

No. Z2 083334 0048 Rev. 13

**Holder of Certificate:** **Ningbo Ulica Solar Co., Ltd.**

NO.181-197, Shanshan Road  
Wangchun Industrial District  
315177 Ningbo  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:**

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704061806602-13

**Valid until:** 2028-07-05

**Date,** 2023-07-06

( Zhulin Zhang )

# CERTIFICATE

No. Z2 083334 0048 Rev. 13

## Model(s):

**1000 V DC system voltage Single Glass modules:**  
 UL-xxxM-72, xxx= 330 to 390 in step of 5  
 UL-xxxM-60, xxx= 275 to 325 in step of 5  
 UL-xxxM-54, xxx= 245 to 290 in step of 5  
 UL-xxxM-48, xxx= 220 to 260 in step of 5  
 UL-xxxM-24, xxx= 110 to 130 in step of 5  
**1500 V DC system voltage Single Glass modules:**  
 UL-xxxM-72HV, xxx= 330 to 390 in step of 5  
 UL-xxxM-60HV, xxx= 275 to 325 in step of 5  
 UL-xxxM-54HV, xxx= 245 to 290 in step of 5  
 UL-xxxM-48HV, xxx= 220 to 260 in step of 5  
 UL-xxxM-24HV, xxx= 110 to 130 in step of 5

**Half cell 1000 V DC system voltage Single Glass modules:**  
 UL-xxxM-144, xxx= 370 to 415 in step of 5  
 UL-xxxM-120, xxx= 305 to 345 in step of 5  
 UL-xxxM-108, xxx= 275 to 310 in step of 5  
 UL-xxxM-96, xxx= 245 to 275 in step of 5  
 UL-xxxM-144, xxx= 420 to 460 in step of 5  
 UL-xxxM-120, xxx= 350 to 380 in step of 5  
 UL-xxxM-108, xxx= 315 to 345 in step of 5  
 UL-xxxM-96, xxx= 280 to 305 in step of 5  
 UL-xxxM-156, xxx= 565 to 600 in step of 5  
 UL-xxxM-144, xxx= 525 to 555 in step of 5  
 UL-xxxM-132, xxx= 480 to 505 in step of 5  
 UL-xxxM-120, xxx= 435 to 460 in step of 5  
 UL-xxxM-108, xxx= 390 to 415 in step of 5  
 UL-xxxM-96, xxx= 350 to 370 in step of 5  
 UL-xxxM-132, xxx= 640 to 670 in step of 5  
 UL-xxxM-120, xxx= 580 to 605 in step of 5  
 UL-xxxM-108, xxx= 525 to 545 in step of 5  
 UL-xxxM-156N, xxx= 590 to 630 in step of 5  
 UL-xxxM-144N, xxx= 545 to 580 in step of 5  
 UL-xxxM-132N, xxx= 500 to 530 in step of 5  
 UL-xxxM-120N, xxx= 455 to 485 in step of 5  
 UL-xxxM-108N, xxx= 410 to 435 in step of 5  
 UL-xxxM-96N, xxx= 365 to 385 in step of 5

**Half cell 1500 V DC system voltage Single Glass modules:**  
 UL-xxxM-144HV, xxx= 370 to 415 in step of 5  
 UL-xxxM-120HV, xxx= 305 to 345 in step of 5  
 UL-xxxM-108HV, xxx= 275 to 310 in step of 5  
 UL-xxxM-96HV, xxx= 245 to 275 in step of 5  
 UL-xxxM-144HV, xxx= 420 to 460 in step of 5  
 UL-xxxM-120HV, xxx= 350 to 380 in step of 5  
 UL-xxxM-108HV, xxx= 315 to 345 in step of 5  
 UL-xxxM-96HV, xxx= 280 to 305 in step of 5  
 UL-xxxM-156HV, xxx= 565 to 600 in step of 5  
 UL-xxxM-144HV, xxx= 525 to 555 in step of 5  
 UL-xxxM-132HV, xxx= 480 to 505 in step of 5  
 UL-xxxM-120HV, xxx= 435 to 460 in step of 5  
 UL-xxxM-108HV, xxx= 390 to 415 in step of 5  
 UL-xxxM-96HV, xxx= 350 to 370 in step of 5  
 UL-xxxM-132HV, xxx= 640 to 670 in step of 5  
 UL-xxxM-120HV, xxx= 580 to 605 in step of 5  
 UL-xxxM-108HV, xxx= 525 to 545 in step of 5  
 UL-xxxM-156HVN, xxx= 590 to 630 in step of 5  
 UL-xxxM-144HVN, xxx= 545 to 580 in step of 5  
 UL-xxxM-132HVN, xxx= 500 to 530 in step of 5  
 UL-xxxM-120HVN, xxx= 455 to 485 in step of 5  
 UL-xxxM-108HVN, xxx= 410 to 435 in step of 5  
 UL-xxxM-96HVN, xxx= 365 to 385 in step of 5  
 xxx is standing for rated output power at STC



# CERTIFICATE

No. Z2 083334 0048 Rev. 13

**Parameters:**

Construction:	Framed, with Junction box, Cable and Connectors.
Fire Safety Class:	Class C according to UL790
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute; No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1000 V DC or 1500 V DC

**Tested  
according to:**

IEC 61215-1:2016  
IEC 61215-1-1:2016  
IEC 61215-2:2016  
IEC 61730-1:2016  
IEC 61730-2:2016