

# CERTIFICATE OF CONFORMITY

This Certificate is issued to

**REC SOLAR PTE LTD**

**(UEN No.: 200723409E)**

**20 Tuas South Avenue 14, Logos Tuas Logistics Hub, Singapore 637312**

**For Product Certification Scheme: Type 2**

**Product : Solar Photovoltaic (PV) Roof-Mounted Module**

**Brand : REC Solar**

**Model : RECxxxTP5 (where xxx = 395 - 415)  
RECxxxTP5 Black (where xxx = 390 – 410)**

**Country of Origin : Singapore**

**Product Details : Monocrystalline silicon photovoltaic module  
Maximum System Voltage: 1000V  
Dimension: 1899 x 1040 x 30 mm  
No. of Cells: 132 half-cut monocrystalline cells  
Fire Rating: Class C**

which has complied with the requirements of the scheme based on the following:

<b>STANDARD(S)</b>	<b>TEST REPORT(S)</b>
IEC 61730-2: 2016	UL Test Report No.: 4790712083 UL Test Report No.: 4790712068 VDE Test Report No.: TRPVM-2022-40598-1

**Detailed configuration and installation shall be referenced to the certified report(s) stated above.**



**Dixon Ng (Mr)**  
Program Manager  
SETSCO Services Pte Ltd  
531 Bukit Batok Street 23,  
Singapore 659547

**Certificate No**  
**FSP-2023-1323**

**Date of Issue**  
**24/02/2023**

**Date of Expiry**  
**23/02/2028**

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at [www.setsco.com](http://www.setsco.com)

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.